




TYPICAL SECTION

- NOTES:
1. BARRIER SHALL BE CONSTRUCTED USING CONCRETE MIX NO. 6 (4500 PSI) AND THE FOOTER SHALL BE CONSTRUCTED USING CONCRETE MIX NO. 2 (3000 PSI). BARRIER AND FOOTER SHALL BE CAST SEPARATELY. MONOLITHIC PLACEMENT NOT PERMITTED.
  2. ALL LONGITUDINAL BARS SHOWN WITHOUT SIZE SPECIFIED SHALL BE NO. 4 BARS AT 1'-6" C/C.
  3. ALL REINFORCEMENT BARS, INCLUDING ENDS, SHALL BE EPOXY COATED. ALL BAR LAPS TO BE 30 BAR DIAMETERS. TIE BARS TOGETHER. ALL BARS SHALL BE ASTM A615, GRADE 60.
  4. SEE STANDARD SHA MD 648.44-05 FOR CONTRACTION AND EXPANSION JOINTS.
  5. COST OF THE CONCRETE FOOTER, ALL REINFORCEMENT, DRAINAGE APPURTENANCES, GEOTEXTILE, JOINT MATERIAL, EXCAVATION, BACKFILL, LABOR, TOOLS, EQUIPMENT, ETC. AND ALL INCIDENTALS SHALL BE INCLUDED IN THE CONTRACT UNIT PRICE PER LINEAR FOOT FOR 42 INCH F SHAPE CONCRETE MEDIAN TRAFFIC BARRIER BIFURCATED 4 FEET 0 INCHES TO 8 FEET 0 INCHES.
  6. TOLERANCES IN DIMENSIONS SHOWN SHALL BE WITHIN 1/4"

	APPROVED:  DIVISION CHIEF, TRANSPORTATION ENGINEERING AND CONSTRUCTION  DIRECTOR, DEPARTMENT OF TRANSPORTATION	CITY OF BALTIMORE DEPARTMENT OF TRANSPORTATION ENGINEERING AND CONSTRUCTION	ISSUED 8 / 2010	REVISED	REVISED
	42 INCH F SHAPE CONCRETE MEDIAN TRAFFIC BARRIER BIFURCATED 4'- 0" TO 8'-0"			STANDARD NO. BC 648.08	
			SCALE: NONE	SHEET 1 OF 1	