




- NOTES:
1. FOR CURB SETBACK, SEE STD. NO. BC 853.01.
 2. CONCRETE SHALL BE MIX 3.

	4" SERV. 3" METER	6" SERV. 4" METER	6" SERV. 3" METER
A	8'-4"	9'-10"	9'-10"
B	4'-6"	5'-6"	5'-6"
C	9"	9"	9"
D	2'-3"	2'-9"	2'-9"
E	9"	9"	11 1/2"
F	11"	15 1/2"	15 1/2"
G	2'-8"	2'-8"	2'-8"
H	3'-0"	3'-6"	3'-6"
L	4'-11"	5'-8"	5'-8"
N	6"	6"	6"
P	24"	24"	24"
R	4'-6" 5'-0"	4'-3" 4'-9"	4'-6" 5'-0"
S	14"	17"	14"
①	#4@12	#4@12	#4@12
②	#5@6	#5@6	#5@6
ML	24"	29"	24"

	APPROVED:  HEAD, BUREAU OF WATER AND WASTEWATER	CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER	ISSUED 3 / 2008	REVISED	REVISED
	 DIRECTOR, DEPARTMENT OF PUBLIC WORKS	STANDARD INSTALLATION OF 4" & 6" WATER SUPPLY SERVICES (3" & 4" METERS WITH REDUCERS)	STANDARD NO. BC 842.02		
			SCALE: NONE	SHEET 1 OF 1	