




NOTE: ALL JOINTS MUST BE RESTRAINED BACK TO MAIN (ALL-THREAD RODS ARE NOT ACCEPTABLE).

	APPROVED:  HEAD, BUREAU OF WATER AND WASTEWATER	CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER	ISSUED	REVISED	REVISED
	 DIRECTOR, DEPARTMENT OF PUBLIC WORKS		3 / 2008		
	STANDARD INSTALLATION OF 4" & 6" WATER SUPPLY SERVICES (3", 4", & 6" METERS) WITH TEE AND VALVE (SECTIONAL VAULT)		STANDARD NO. BC 843.02		
			SCALE: NONE	SHEET 1 OF 1	