




	4" F.M. WITH 4" DOM. METER AND 4" BYPASS	6" F.M. WITH 4" DOM. METER AND 4" BYPASS	8" F.M. WITH 6" DOM. METER AND 6" BYPASS	8" F.M. WITH 4" DOM. METER AND 4" BYPASS	10" F.M. WITH 6" DOM. METER AND 6" BYPASS	10" F.M. WITH 4" DOM. METER AND 4" BYPASS
SIZE	4"	6"	8"	8"	10"	10"
A	6'-10"	6'-11 1/2"	8'-2"	7'-5"	9'-2"	9'-2"
B	7'-10"	7'-7"	8'-9 1/2"	8'-1 1/2"	9'-9"	9'-1"
C	9"	9"	9"	9"	9"	9"
D	2'-10"	3'-3"	3'-9"	3'-9"	4'-6"	4'-6"
D1	4'-2"	4'-4"	5'-1 1/2"	4'-4 1/2"	5'-3"	4'-7"
E	9"	9"	9"	9"	9"	9"
F	9"	9"	9"	—	—	—
G	2'-8"	2'-5"	2'-2"	2'-2"	2'-2"	2'-2"
H	3'-7"	4'-0"	4'-6"	4'-6"	5'-3"	5'-3"
L	3'-11 1/2"	4'-8 1/2"	5'-2 1/2"	5'-2 1/2"	6'-2"	6'-2"
N	6"	6"	6"	6"	6"	6"
P	30"	30"	30"	30"	30"	30"
R	4'-4" 4'-10"	4'-4" 4'-10"	4'-4" 4'-10"	4'-4" 4'-10"	3'-8" 4'-2"	3'-8" 4'-2"
S	1'-2 1/2"	1'-5 1/2"	1'-9 1/2"	1'-9 1/2"	2'-6"	2'-6"
F1	—	—	—	9"	11"	11"

NOTE: FOR 12" F.M. USE 10" F.M. VAULT WITH CORRESPONDING DOMESTIC METERS & BYPASS SIZES.

	APPROVED:	CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER	ISSUED	REVISED	REVISED
	 HEAD, BUREAU OF WATER AND WASTEWATER  DIRECTOR, DEPARTMENT OF PUBLIC WORKS		REBAR SCHEDULE FOR STANDARD VAULT FOR 4", 6", 8", 10", & 12" F.M. METERS WITH LARGE DOMESTIC METERS	3 / 2008	
			STANDARD NO. BC 848.01		
			SCALE: NONE	SHEET 2 OF 3	