


NOTE:
MAKE HOLES IN ANGLE STRAP 1/8" LARGER THAN DIAMETER OF BOLT.

SIZE OF MAIN	SIZE OF ANGLE STRAP	RADIUS OF STRAP "R"	DISTANCE OF HOLES C TO C "E"	DIA. OF BOLT "F"	EDGE DIST. "G"	"H"
4"	3"x3"x3/8"	2 1/2"	11"	3/4"	2"	1"
6"	3"x3"x3/8"	3 9/16"	12 1/2"	3/4"	2"	1"
8"	3"x3"x3/8"	4 21/32"	15"	7/8"	2"	1 1/4"
10"	4"x3"x3/8"	5 23/32"	17 1/2"	1 1/8"	2"	1 1/4"
12"	5"x4"x3/8"	6 3/4"	20 3/16"	1 1/2"	2 1/4"	1 1/2"
16"	6"x4"x1/2"	8 29/32"	25 1/4"	1 5/8"	2 1/2"	1 1/2"
20"	6"x4"x3/4"	11 1/32"	30 7/8"	2 1/4"	3 5/8"	1 3/4"



APPROVED :
[Signature]
HEAD, BUREAU OF WATER AND WASTEWATER
[Signature]
DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
DEPARTMENT OF PUBLIC WORKS
BUREAU OF WATER AND WASTEWATER

STANDARD
PLUG CLAMPS - 2

ISSUED	REVISED	REVISED
3 / 2008		
STANDARD NO. BC 858.01		
SCALE : NONE	SHEET 2 OF 2	